

## Annexure - C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 781

Dated : 28/04/26

It is certified that an inspection team headed by Shashi Kant Kuroso  
Chemist (Name of Officers with designation)

from CHEMIST P.H. DIVISION SHBIKHPURA PHED

inspected the **Divine Light Public School, West to Gramin Bank / Sahara India, Barbigha, Sheikhpura, Bihar - 811101** (Name & Address of the school) on 02/04/26

(date of inspection) and on the basis of Water Test Report (Attached) bearing no. SHPL/2528/R/09

dated 08.04.2026 of DLWPL P.H. DIVISION PHED Lab certified that the

**Divine Light Public School** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt.

This certificate is valid till Six Months

Signature with Seal : Ranjit Kumar Singh

Name

Ranjit Kumar Singh

Designation

EXECUTIVE ENGINEER

Name & Address of the Office / Department :

PHED  
28/04/26

To,

**DIVINE LIGHT PUBLIC SCHOOL**  
**West to Gramin Bank / Sahara India,**  
**Barbigha, Sheikhpura (Bihar) - 811101**  
(Name & Address of the Institution)

**Note: The certificate is to be issued by authorized office / PHED Lab / local bodies**



Government of Bihar  
Public Health Engineering Department  
District Level Water Testing Laboratory  
Sheikhpura, Near Jakhraj Asthan,  
Dist-Sheikhpura, Bihar Pin-811105

Email id-shashikant88kumar@gmail.com. Mob:- 9006336473



DOC No: SHP\SAMP\05\00

**TEST REPORT**

Name & Address Of the Customer Rajesh Kumar Block-Barbigha Panchayat-Barbigha Village-Barbigha Divine Light Public School	URL NO-	TC15433250000002F
	Report No.	: SHP/W/26-27/R/02
	Date	: 02.04.2026
	Sample No.	: SHP/W/26-27/02
	Sample Description	: Drinking Water
	Sample Mark/ Location	: Divine Light Public School
	Sample Collected On	: 02.04.2026
	Sampling Plan & Method	: IS 17614 Part-1 2021
	Sample Submitted On	: 02.04.2026
	Date of Performance (s)	: 02.04.2026 to 08.04.2026
	Ref No. Date	:

**Analysis Result**

SL No.	Test Parameter	Test Method	IS 10500:2012Amd. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	pH Value in 25°C	IS 3025(Part 11) : 2022	6.5.8.5	No Relaxation	7.4
2	Turbidity in NTU	IS 3025 (Part 10) :2024	1	5	1.0
3	TDS in mg/l	IS 3025(Part 16) : 2023	500	2000	116.6
4	Total Hardness in mg/l	IS 3025(Part 21) : 2019	200	600	78.40
5	Calcium in mg/l	IS 3025(Part 40) : 2024	75	200	16.68
6	Magnesium in mg/l	APHA 24th Edition -3500- Mg B; 2023	30	100	8.56
7	Iron in mg/l	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method) : 2023	1	No Relaxation	0.12
8	Chloride in mg/l	IS 3025(Part 32) : 2025	250	1000	9.78
9	Total Alkalinity in mg/l	IS 3025(Part 23) : 2023	200	600	44.44
10	Colour in HU	IS 3025 (Part 4) : 2021	5	15	<1
11	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable
12	Taste	IS 3025 (Part 8) : 2023	Agreeable	Agreeable	Agreeable
13	Fluoride mg/l	APHA 24th Edition -4500F C; 2023	1	1.5	0.69

For District Level Water Testing Laboratory, Sheikhpura  
Reviewed & Authorized By



End of Report

- The results relate only to the items(s) tested.
- This Test Report shall not reproduced without the permission of District Level Water Testing Laboratory, Sheikhpura
- The reserved part of sample(s), except perishable sample(s), shall be retained for 15 day's from the date of issue of the Test report.